



1 EU – Type Examination Certificate

2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU

3 EU – Type Examination Certificate Number: **KIWA 17ATEX0055 X Issue: 1**

4 Product: **Temperature Transmitter, Model IPAQ R530X**

5 Manufacturer: **INOR Process AB**

6 Address: **Travbanegatan 10, 213 77 Malmö
Sweden**

7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Kiwa Nederland B.V., Notified Body number 0620 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.
The examination and test results are recorded in confidential ATEX Assessment Report No. 171101122-1.

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0 : 2012 + A11 : 2013 EN 60079-11 : 2012

10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU – Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:



II 1 G Ex ia IIC T6 ... T4 Ga

Kiwa Nederland B.V.
Unit Kiwa ExVision
Wilmsdorf 50
P.O. Box 137
7300 AC Apeldoorn
The Netherlands

Tel. +31 88 998 34 93
Fax +31 88 998 36 85
ExVision@kiwa.nl
www.kiwaexvision.com

Kiwa Nederland B.V.

Pieter van Breugel
Certification Officer

Issue date:

15 March 2018

First issue:

This certificate shall, as far as applicable, be revised before the date of cessation of presumption of conformity of (one of) the included standards above as communicated in the Official Journal of the European Union.

© Integral publication of this certificate in its entirety and without any change is allowed.

13 SCHEDULE

14 EU – Type Examination Certificate KIWA 17ATEX0055 X Issue No. 1

15.1 Description of Product

Rail mounted Temperature Transmitter Model IPAQ R530X, with a non-metallic enclosure, is a loop powered device that converts the measurement signals of temperature sensors (RTD or thermocouple) or resistance or mV signals into a 4 - 20 mA output signal with HART communication.

The transmitter is provided with a USB port and NFC technology for service and configuration.

15.2 Electrical Data

Supply and output circuit (terminals 21 and 22):

In type of protection intrinsic safety Ex ia IIC, only for connection to a certified intrinsically safe circuit; with following maximum values:

$U_i = 30 \text{ V}$; $I_i = 100 \text{ mA}$; $P_i = 0,9 \text{ W}$; $C_i = 23,1 \text{ nF}$; $L_i = 20 \text{ }\mu\text{H}$.

Sensor circuits (terminals 1 ... 4):

In type of protection intrinsic safety Ex ia IIC, with following maximum values:

$U_o = 6,5 \text{ V}$; $I_o = 11,7 \text{ mA}$; $P_o = 19,1 \text{ mW}$; $C_o = 24 \text{ }\mu\text{F}$; $L_o = 400 \text{ mH}$.

Communication port (mini USB connector):

Only for connection to the associated ICON-X or ICON Interface.

15.3 Thermal data

Ambient temperature range: -40 °C to +60 °C for temperature class T6;
 -40 °C to +75 °C for temperature class T5;
 -40 °C to +85 °C for temperature class T4.

15.4 Instructions

The instructions provided with the product shall be followed in detail to assure safe operation.

16 ATEX Assessment Report Number

171101122-1.

17 Specific Conditions of Use

- The communication port (USB connection) may only be connected to the associated ICON Interface if the temperature transmitter is outside of the hazardous area.
If certified ICON-X interface is used, a connected sensor may be located in the hazardous area.
If non-Ex ICON interface is used, a connected sensor shall not be located in the hazardous area.
- For the applicable ambient temperature range, refer to section 15.3.
- The transmitter shall be mounted into a suitable enclosure that provides a degree of protection of at least IP20.



13 **SCHEDULE**

14 **EU – Type Examination Certificate KIWA 17ATEX0055 X Issue No. 1**

18 **Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at section 9.

19 **Drawings and Documents**

As listed in ATEX Assessment Report No. 171101122-1.

>

